

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

## PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND

### DETAILS OF THE CONTRACTOR

Registration No: [REDACTED] Branch No: [REDACTED]  
 Trading Title: [REDACTED]  
 Address: [REDACTED]  
 Postcode: [REDACTED] Tel No: [REDACTED]

### DETAILS OF THE CLIENT

Contractor Reference Number (CRN): N/A  
 Name: Shaftesbury Town Council  
 Address: The Town Hall, The High Street, Shaftesbury, Dorset  
 Postcode: SP7 8LY Tel No: N/A

### DETAILS OF THE INSTALLATION

Occupier: Shaftesbury Town Council  
 Address: The Town Hall, The High Street, Shaftesbury, Dorset  
 Postcode: SP7 8LY Tel No: N/A

## PART 2 : PURPOSE OF THE REPORT

### Purpose for which this report is required:

Scheduled report.

(see additional page No. N/A)

Date(s) when inspection and testing was carried out: (05/10/2022)

Records available: (N/A)

Previous inspection report available: (N/A)

Previous report date: ( )

## PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

### General condition of the installation (in terms of electrical safety):

Requires improvement to be deemed as safe.

(see additional page No. N/A)

Estimated age of electrical installation: (40/50) years

Evidence of additions or alterations: (Yes)

Overall assessment of the installation is: **Unsatisfactory\***

## PART 4 : DECLARATION

### INSPECTION AND TESTING

I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 7, having exercised reasonable skill and care when carrying out the inspection and testing of the existing installation, hereby CERTIFY that the information in this report, including the observations (page 2) and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

Name (capitals): [REDACTED]

Signature: [REDACTED]

Date: 10/10/2022

### REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE APPROVED CONTRACTOR

Name (capitals): [REDACTED]

Signature: [REDACTED]

Date: 10/10/2022

\*An unsatisfactory assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified in PART 6, or that Further Investigation (CODE F1) without delay is required

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

## PART 5 : NEXT INSPECTION

I/We (as indicated on page 1) recommend, subject to the necessary remedial work being taken, this installation should be further inspected and tested after an interval of not more than 5 years\*

Give reason for recommendation: Commercial/ publicly accessed property.

(see additional page No. N/A)

## PART 6 : OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

**CODES:** One of the following Codes, as appropriate, has been allocated to each of the observations made below to indicate to the person(s) responsible for the electrical installation the degree of urgency for remedial action

**CODE C1 'Danger Present'**  
Risk of injury. Immediate remedial action required

**CODE C2 'Potentially Dangerous'**  
Urgent remedial action required

**CODE C3**  
'Improvement Recommended'

**CODE F1**  
'Further Investigation Required'

Referring to the Schedule of Items Inspected (see PART 10), the attached Schedule of Circuit Details and Test Results (see PART 12), and subject to any agreed limitations listed in PART 7:

There are no items adversely affecting electrical safety  , OR The following observations and recommendations for action are made:

Item No	Observation(s)	Code	Location Reference
1	SOCKET CIRCUIT HAS NO RING CONTINUITY AND REQUIRES INVESTIGATION.	C2	DB3-2
2	CAN NOT LOCATE UPSTAIRS WATER HEATER CIRCUIT.	FI	DB1-3
3	CAN NOT LOCATE SOCKET CIRCUIT.	FI	DB1-11
4	LIVE CABLE WITH SMALL AMOUNT OF TAPE PROTECTING THE CONDUCTOR IN CORNER OF HALL BY WINDOW. NEUTRAL CONDUCTOR IS EXPOSED.	C1	N/A
5	TAILS FEEDING THE SOLAR PV BOARD HAVE BEEN CONNECTED IN THE SAME TERMINAL AS THE INCOMING TAILS OF DB1. NO THERMAL DAMAGE PRESENT AND TAILS SEEM TO BE WELL CONNECTED BUT A BETTER SOLUTION IS RECOMMENDED.	C3	DB1- SOLAR PV
6	PIR IN DISABLED WC REQUIRES REPLACEMENT DUE TO NOT MEETING MINIMUM REQUIRED IP RATING AND FIXING INTO THE FABRIC OF THE BUILDING REQUIRES IMPROVEMENT.	C2	DB2-1
7	SOLAR PV HAS THE WRONG TYPE OF RCD, TYPE A REQUIRED DUE TO DC CHARACTERISTICS OF THE INSTALLATION.	C3	DB3
8	HEATING DB DOES NOT MEET MINIMUM REQUIRED IP RATING DUE TO LARGE ENTRY HOLE IN THE BOTTOM.	C2	DB4
9	CAN NOT LOCATE HEAT PUMP ISOLATORS TO CONDUCT TESTING, HEATERS MAY NEED TO BE DISMANTLED TO OBTAIN READINGS.	FI	DB4
10	CAN NOT LOCATE SOLAR PV INVERTER TO CONDUCT TESTING.	FI	SOLAR PV
11	ALL CABLING IS VERY OLD AND SOCKET CABLES ONLY APPEAR TO HAVE 1MM EARTHS. DOWNGRADE OF CIRCUITS MAY BE REQUIRED FOLLOWING CALCULATIONS.	FI	DB1
12	NO SPD PRESENT,	C3	DB1
13	CABLES BURIED IN THE WALL LESS THAN 50MM HAVE NO 30 MA RCD PROTECTION.	C3	DB1
14	CONSUMER UNITS ARE VERY OLD, AN UPGRADE WOULD BE BENEFICIAL DUE TO NOT BEING FIRE RATED. LOCATION OF THESE IS ALSO QUESTIONABLE AS THEY ARE HARD TO GAIN ACCESS TO TO CONDUCT ANY TESTING/ MAINTENANCE.	C3	DB2/ DB4
15	GAS APPEARS PRESENT ON SITE, THIS HAS NOT BEEN LOCATED TO CHECK FOR BONDING.	FI	GAS

Additional pages? (N/A ) State page numbers: (N/A )

Immediate action required for items: (4 ) Improvement recommended for items: (5,7,12,13,14 )

Urgent remedial action required for items: (1,6,8 ) Further investigation required for items: (2,3,9,10,11,15 )

\*The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life  
The period should be agreed between relevant parties

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

## PART 7 : DETAILS AND LIMITATIONS OF THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671: 2018, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

**Details of the installation covered by this report:**

All circuits tested. Fixed wiring only.

(see additional page No. N/A)

**Agreed limitations including the reasons, if any, on the inspection and testing:**

Loft not entered. Floor not lifted. Supply into DB1 and DB3 treated as origin for the purpose of the test, actual origin is located in the salt cellar. Insulation resistance testing has been omitted due to sensitive electronics on the circuits that can not be seen and/or disconnected.

(see additional page No. N/A)

Agreed with (print name): CLIENT

Extent of sampling: 25%

(see additional page No. N/A)

Operational limitations including the reasons: N/A

(see additional page No. N/A)

Origin of the person ordering the work

## PART 8 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements			Number and type of live conductors			Nature of supply parameters		
TN-C-S: <input checked="" type="checkbox"/>	TN-S: <input type="checkbox"/>	TT: <input type="checkbox"/>	AC	1-phase, 2-wire: <input type="checkbox"/>	2-phase, 3-wire: <input type="checkbox"/>	Nominal line voltage, $U^{(1)}$ : (230) V		
Other (state) N/A			DC	3-phase, 3-wire: <input type="checkbox"/>	3-phase, 4-wire: <input checked="" type="checkbox"/>	Nominal line voltage to Earth, $U_0^{(1)}$ : (230) V		
Supply protective device			DC	2-wire: <input type="checkbox"/>	3-wire: <input type="checkbox"/>	Nominal frequency, $f^{(1)}$ : (50) Hz		
(BS (EN) 88 Fuse HRC		)	Confirmation of supply polarity: (✓)		Other: (N/A)	Prospective fault current, $I_{pf}^{(1)*}$ : (0.9) kA		
Type: (gG		)	Rated current: (60) A		Other sources of supply: (as detailed on attached schedule)	External loop impedance, $Z_e^{(1)*}$ : (0.26) Ω		
					Page No: (N/A)			

## PART 9 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS CERTIFICATE

Means of Earthing	Main protective conductors	Main protective bonding connections	Main switch / Switch-fuse / Circuit-breaker / RCD
Distributor's facility: (✓)	Earthing conductor: (material Copper csa 16 mm <sup>2</sup> )	Water installation pipes: (✓)	Type: (BS (EN) BS EN 60947-3)
Installation earth electrode: (N/A)	Connection / continuity verified: <input checked="" type="checkbox"/>	Gas installation pipes: (FI)	Location: (DB)
Where an earth electrode is used insert	Main protective bonding conductors: (material Copper csa 10 mm <sup>2</sup> )	Structural steel: (N/A)	No. of poles: (2)
Type - rod(s), tape, etc: (N/A)	Connection / continuity verified: <input checked="" type="checkbox"/>	Oil installation pipes: (N/A)	Rating / setting of device: (N/A) A
Location: (N/A)		Lightning protection: (N/A)	Current rating: (100) A
Electrode resistance to Earth: (N/A) Ω		Other (state): N/A	Voltage rating: (230) V
		RCD rated residual operating current, $I_{dn}$ : (N/A) mA	
		Measured operating time: (N/A) ms	Rated time delay: (N/A) ms

 \*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current,  $I_{pf}$ , and external earth fault loop impedance,  $Z_e$ , must be recorded

All fields must be completed. Enter either, as appropriate: '✓' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists; or Code appropriately - CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

## PART 10 : SCHEDULE OF ITEMS INSPECTED

### 1. External condition of electrical intake equipment (visual inspection only)

(If inadequacies are identified with the intake equipment, it is recommended the person ordering the report informs the appropriate authority.)

1.1 Service cable: (  ) 1.2 Service head: (  )

1.3 Earthing arrangement: (  ) 1.4 Meter tails: (  )

1.5 Metering equipment: (  ) 1.6 Isolator (where present): (  )

### 2. Presence of adequate arrangements for parallel or switched alternative sources

2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply: (  )

2.2 Adequate arrangements where generating set operates in parallel with the public supply: (  )

2.3 Presence of alternative / additional supply arrangement warning notice(s) at or near equipment, where required: (  )

### 3. Automatic disconnection of supply

#### 3.1 Main earthing and bonding arrangements

a) Presence and condition of distributor's earthing arrangement: (  )

b) Presence and condition of earth electrode arrangement, if present: (  )

c) Adequacy of earthing conductor size: (  )

d) Adequacy of earthing conductor connections: (  )

e) Accessibility of earthing conductor connections: (  )

f) Adequacy of main protective bonding conductor size(s): (  )

g) Adequacy of main protective bonding conductor connections: (  )

h) Accessibility of main protective bonding connections: (  )

i) Accessibility and condition of other protective bonding connections: (  )

j) Provision of earthing / bonding labels at all appropriate locations: (  )

#### 3.2 FELV

a) Source providing at least simple separation: (  )

b) Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises: (  )

### 4. Other methods of protection (N/A)

Details should be provided on separate sheets: Page No. (N/A)

### 5. Distribution equipment

5.1 Adequacy of working space / accessibility of equipment: (  )

5.2 Security of fixing: (  )

5.3 Condition of insulation of live parts: (  )

5.4 Adequacy / security of barriers: (  )

5.5 Condition of enclosure(s) in terms of IP rating: (  )

5.6 Condition of enclosure(s) in terms of fire rating: (  )

5.7 Enclosure not damaged / deteriorated so as to impair safety: (  )

5.8 Presence and effectiveness of obstacles: (N/A)

5.9 Presence of main switch(es), linked where required: (  )

5.10 Operation of main switch(es) (functional check): (  )

5.11 Correct identification of circuit protective devices: (  )

5.12 Adequacy of protective devices for prospective fault current: (  )

5.13 RCD(s) provided for fault protection – includes RCBOs: (N/A)

5.14 RCD(s) provided for additional protection – includes RCBOs: (  )

5.15 RCD(s) provided for protection against fire – includes RCBOs: (N/A)

5.16 Manual operation of circuit-breakers and RCDs to prove disconnection: (  )

5.17 Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check): (  )

5.18 Presence of RCD six-monthly retest notice at or near equipment, where required: (  )

5.19 Presence of diagrams, charts or schedules at or near equipment, where required: (  )

5.20 Presence of non-standard (mixed) cable colour warning notices at or near equipment, where required: (  )

5.21 Presence of next inspection recommendation label: (  )

5.22 All other required labelling provided: (  )

5.23 Compatibility of protective device(s), base(s) and other components: (  )

5.24 Single-pole switching or protective devices in line conductors only: (  )

5.25 Protection against mechanical damage where cables enter equipment: (  )

5.26 Protection against electromagnetic effects where cables enter ferrromagnetic enclosures: (  )

### 6. Distribution / final circuits

6.1 Identification of conductors: (  )

6.2 Cables correctly supported throughout their length: (LIM)

6.3 Condition of insulation of live parts: (  )

6.4 Non-sheathed cables protected by enclosures in conduit, ducting or trunking: (  )

6.5 Suitability of containment systems for continued use (including flexible conduit): (  )

6.6 Cables correctly terminated in enclosures (indicate extent of sampling in PART 7 of report): (  )

6.7 Indication of SPD(s) continued functionality confirmed: (  )

6.8 Adequacy of AFDD(s), where specified: (  )

6.9 Confirmation that conductor connections, including connections to busbars are correctly located in terminals and are tight and secure: (  )

6.10 Examination of cables for signs of unacceptable thermal and mechanical damage / deterioration: (  )

6.11 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation: (  )

6.12 Adequacy of protective devices; type and rated current for fault protection: (  )

6.13 Presence and adequacy of circuit protective conductors: (  )

6.14 Co-ordination between conductors and overload protective devices: (  )

6.15 Cable installation methods / practices appropriate to the type and nature of installation and external influences: (LIM)

6.16 Cables where exposed to direct sunlight, of a suitable type or adequately protected against solar radiation: (  )

6.17 Cables adequately protected against damage and abrasion: (  )

All fields must be completed. Enter either, as appropriate: '  ' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists; or Code appropriately - CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)

Original to the person ordering the work

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

## PART 10 : SCHEDULE OF ITEMS INSPECTED

6.18 Provision of additional protection by an RCD not exceeding 30 mA	6.26 Single-pole switching or protective devices in line conductors only:	( ✓ )	8. Current-using equipment (permanently connected)	
a) For all socket-outlets with a rated current not exceeding 32 A, unless exempt:	6.27 Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment:	( ✓ )	8.1 Condition of equipment in terms of IP rating:	( ✓ )
b) Supplies for mobile equipment with a rated current not exceeding 32 A for use outdoors:	<b>7. Isolation and switching</b>		8.2 Equipment does not constitute a fire hazard:	( ✓ )
c) For cables concealed in walls / partitions at a depth of less than 50 mm:	7.1 Isolators		8.3 Enclosure not damaged / deteriorated so as to impair safety:	( ✓ )
d) For cables concealed in walls / partitions containing metal parts regardless of depth:	a) Presence and condition of appropriate devices:	( ✓ )	8.4 Suitability for the environment and external influences:	( ✓ )
e) Circuits supplying luminaires within domestic (household) premises:	b) Acceptable location (local / remote):	( ✓ )	8.5 Security of fixing:	( ✓ )
<i>Note Older installations designed prior to BS 7671 2018 may not have been provided with RCDs for additional protection</i>	c) Capable of being secured in the OFF position:	( ✓ )	8.6 Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire:	( ✓ )
6.19 Provision of fire barriers, sealing arrangements and protection against thermal effects:	d) Correct operation verified:	( ✓ )	List number and location of luminaires inspected on a separate page:	Page No. (N/A)
6.20 Band II cables segregated / separated from Band I cables:	e) Clearly identified by position and / or durable markings:	( ✓ )	8.7 Recessed luminaires (e.g. downlighters)	
6.21 Cables segregated / separated from non-electrical services:	f) Warning label posted in situations where live parts cannot be isolated by the operation of a single device:	( ✓ )	a) Correct type of lamps fitted:	( ✓ )
6.22 Termination of cables at enclosures (indicate extent of sampling in PART 7 of report)	7.2 Switching off for mechanical maintenance		b) Installed to minimise build-up of heat:	( ✓ )
a) Connections under no undue strain:	a) Presence and condition of appropriate devices:	( ✓ )	c) No signs of overheating to surrounding building fabric:	( ✓ )
b) No basic insulation of a conductor, visible outside an enclosure:	b) Acceptable location:	( ✓ )	d) No signs of overheating to conductors / terminations:	( ✓ )
c) Connections of live conductors adequately enclosed:	c) Capable of being secured in the OFF position:	( ✓ )	<b>9. List all special installations or locations covered by this report:</b>	
d) Adequacy of connection at point of entry to enclosure:	d) Correct operation verified:	( ✓ )	N/A	(N/A)
6.23 Temperature rating of cable insulation adequate:	e) Clearly identified by position and / or durable marking(s):	( ✓ )	N/A	(N/A)
6.24 Condition of accessories including socket-outlets, switches and joint boxes satisfactory:	7.3 Emergency switching off / stopping		N/A	(N/A)
6.25 Suitability of accessories for external influences:	a) Presence and condition of appropriate devices:	(N/A)	<i>Indicate if the relevant requirements of Part 7 are satisfied and append results of inspection on a separate numbered page</i>	
	b) Readily accessible for operation where danger might occur:	(N/A)		
	c) Correct operation verified:	(N/A)	<b>SCHEDULE OF ITEMS INSPECTED BY</b>	
	7.4 Functional switching		Name (capitals):	
	a) Presence and condition of appropriate devices:	( ✓ )	Signature:	
	b) Correct operation (functionality) verified:	( ✓ )		Date: 10/10/2022

## PART 11 : SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 9. above)	Continuation sheets
Page No(s): ( 4 & 5 )	Page No(s): ( 6 )	Page No(s): (N/A )	Page No(s): (N/A )	Page No(s): (N/A )

The pages identified are an essential part of this report (see Regulation 653.2)

All fields must be completed. Enter either, as appropriate: ' ✓ ' if Acceptable condition; ' N/A ' if Not applicable; ' LIM ' if a Limitation exists; or Code appropriately - CODE ' C1 ', ' C2 ', ' C3 ' or ' F1 ' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)

## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS										Circuits/equipment vulnerable to damage when testing: N/A																
CODES For Type of wiring				(A) Thermoplastic insulated /		(B) Thermoplastic cables in		(C) Thermoplastic cables in		(D) Thermoplastic cables in		(E) Thermoplastic cables in		(F) Thermoplastic / SWA cables		(G) Thermosetting / SWA cables		(H) Mineral-insulated cables		(O) other - state		N/A				
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa		Max disconnection time (BS 7671) (s)	Protective device			RCD Operating current, $I_{An}$ (mA)	Maximum permitted $Z_s$ for installed protective device* ( $\Omega$ )	Circuit impedances ( $\Omega$ )				Insulation resistance			Polarity	Max. measured earth fault loop impedance, $Z_s$ ( $\Omega$ )	RCD operating time (ms)	Test buttons			
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)		Short-circuit capacity (kA)	(Line) $r_1$	(Neutral) $r_m$	(cpc) $r_2$	( $R_1+R_2$ )	$R_2$	(MΩ)	(MΩ)	Test voltage DC (V)			RCD	AFDD		
1	CONTACTOR HEATING	F	B	N/A	16	16	5	60898 MCB	B	32	6	N/A	1.37	N/A	N/A	N/A	0.01	N/A	LIM	LIM	LIM	✓	0.27	N/A		
2	COOKER	A	B	N/A	6	2.5	0.4	60898 MCB	B	32	6	N/A	1.37	N/A	N/A	N/A	0.01	N/A	LIM	LIM	LIM	✓	0.27	N/A		
3	WATER HEATER IN UP TOILETS	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	20	6	N/A	2.19	N/A	N/A	N/A	FI	N/A	FI	FI	FI	FI	N/A			
4	LIGHTING TOILETS	A	B	N/A	1	1	0.4	60898 MCB	B	6	6	N/A	7.28	N/A	N/A	N/A	0.97	N/A	LIM	LIM	LIM	✓	1.23	N/A		
5	COUNCIL CHAMBER MIDDLE DOWNLIGHTS	A	B	N/A	1	1	0.4	60898 MCB	B	6	6	N/A	7.28	N/A	N/A	N/A	1.46	N/A	LIM	LIM	LIM	✓	1.72	N/A		
6	COUNCIL CHAMBER OS DOWNLIGHTS	A	B	N/A	1	1	0.4	60898 MCB	B	6	6	N/A	7.28	N/A	N/A	N/A	1.6	N/A	LIM	LIM	LIM	✓	1.86	N/A		
7	LIGHTING AND CLOCK STRIKER	A	B	N/A	1	1	0.4	60898 MCB	B	6	6	N/A	7.28	N/A	N/A	N/A	0.26	N/A	LIM	LIM	LIM	✓	0.52	N/A		
8	KITCHEN LIGHTING AND LOWER STAIRS	A	B	N/A	1	1	0.4	60898 MCB	B	6	6	N/A	7.28	N/A	N/A	N/A	0.3	N/A	LIM	LIM	LIM	✓	0.56	N/A		
9	LIGHTING MAYORS PARLOUR	A	B	N/A	1	1	0.4	60898 MCB	B	10	6	N/A	4.37	N/A	N/A	N/A	1.23	N/A	LIM	LIM	LIM	✓	1.49	N/A		
10	FIRE ALARM	A	B	N/A	1	1	0.4	60898 MCB	B	10	6	30	4.37	N/A	N/A	N/A	0.35	N/A	LIM	LIM	LIM	✓	0.61	37		
11	SOCKETS COUNCIL CHAMBER OFFICE	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	20	6	30	2.19	N/A	N/A	N/A	FI	N/A	LIM	LIM	LIM	FI	37			
12	SOCKETS KITCHEN	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	16	6	30	2.73	N/A	N/A	N/A	0.12	N/A	LIM	LIM	LIM	✓	0.44	37		
13	SOCKETS HALL	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	32	6	30	1.37	0.3	0.3	0.49	0.2	N/A	LIM	LIM	LIM	✓	0.46	37		
14	CON UNIT CLERKS OFFICE	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	32	6	30	1.37	N/A	N/A	N/A	0.44	N/A	LIM	LIM	LIM	✓	0.7	37		

 DISTRIBUTION BOARD (DB) DETAILS  
(to be completed in every case)

DB designation: DB001--POWER

Location of DB: KITCHEN CUPBOARD

TESTED BY Name (capitals): [REDACTED]

Signature: [REDACTED]

Position: QS/PDH

Date: 05/10/2022

## TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (N/A)

Nominal voltage: (N/A) V No. of phases: (N/A)

Overcurrent protection device for the distribution circuit Type: (BS EN N/A)

Rating: (N/A) A

Associated RCD (if any) Type: (BS EN N/A)

 No. of poles: (N/A)  $I_{An}$  (N/A) mA Operating time: (N/A) ms

 Characteristics at this DB Confirmation of supply polarity: (Yes) Phase sequence confirmed (where appropriate):   $Z_s$  (0.26)  $\Omega$   $Z_f$  (0.9) kA

 TEST INSTRUMENTS  
(enter serial number against each instrument used)

Multi-function: (101909080) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: RCD: (N/A) (N/A)

## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS										Circuits/equipment vulnerable to damage when testing: N/A																
CODES For Type of wiring				(A) Thermoplastic insulated /	(B) Thermoplastic cables in	(C) Thermoplastic cables in	(D) Thermoplastic cables in	(E) Thermoplastic cables in	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	N/A													
Circuit number	Circuit description			Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa		Max disconnection time (BS 7671) (s)	Protective device			RCD Operating current, $I_{an}$ (mA)	Maximum permitted $Z_s$ for installed protective device* ( $\Omega$ )	Circuit impedances ( $\Omega$ )				Insulation resistance			Polarity	Max. measured earth fault loop impedance, $Z_s$ ( $\Omega$ )	RCD operating time (ms)	Test buttons	
							Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)			Short-circuit capacity (kA)	(Line) $r_1$	(Neutral) $r_n$	(cpc) $r_2$	( $R_1+R_2$ )	$R_2$	Live / Live				Live / Earth	Test voltage DC (V)
1	SOLAR PV	A	B	N/A	4	1.5	0.4	60898 MCB	B	20	6	30	2.19	N/A	N/A	N/A	FI	N/A	FI	FI	FI	✓	FI	22	✓	

 DISTRIBUTION BOARD (DB) DETAILS  
(to be completed in every case)

DB designation: DB003-SOLAR

Location of DB: KITCHEN CUPBOARD

TESTED BY Name (capitals): [REDACTED]

Signature: [REDACTED]

Position: QS/PDH

Date: 05/10/2022

## TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (N/A) Nominal voltage: (N/A) V No. of phases: (N/A)

Overcurrent protection device for the distribution circuit Type: (BS EN N/A) Rating: (N/A) A

 Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A)  $I_{an}$  (N/A) mA Operating time: (N/A) ms

 Characteristics at this DB Confirmation of supply polarity: (Yes) Phase sequence confirmed (where appropriate):   $Z_s$  (N/A)  $\Omega$   $Z_f$  (N/A) kA

 TEST INSTRUMENTS  
(enter serial number against each instrument used)

Multi-function: (101909080) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: RCD: (N/A) (N/A)

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS										Circuits/equipment vulnerable to damage when testing: N/A																	
CODES For Type of wiring				(A) Thermoplastic insulated /	(B) Thermoplastic cables in	(C) Thermoplastic cables in	(D) Thermoplastic cables in	(E) Thermoplastic cables in	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	N/A														
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa		Max disconnection time (BS 7671) (s)	Protective device			RCD Operating current, $I_{an}$ (mA)	Maximum permitted $Z_s$ for installed protective device* ( $\Omega$ )	Circuit impedances ( $\Omega$ )				Insulation resistance			Polarity	Max. measured earth fault loop impedance, $Z_s$ ( $\Omega$ )	RCD operating time (ms)	Test buttons				
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)		(Line) $r_1$	(Neutral) $r_m$	(cpc) $r_2$	( $R_1+R_2$ )	$R_2$	Live / Live	Live / Earth	Test voltage DC (V)			RCD	AFDD			
1	LIGHTS	A	B	N/A	1	1	0.4	3036 Fuse (SE)	2	5	6	30	9.1	N/A	N/A	N/A	0.55	N/A	LIM	LIM	LIM	✓	1.25	37	✓		
2	SOCKETS	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	32	6	30	1.37	X	X	X	X	N/A	LIM	LIM	LIM	✓	0.76	37	✓		

**DISTRIBUTION BOARD (DB) DETAILS**  
 (to be completed in every case)

DB designation: DB004-CLERKS OFFICE POWER

Location of DB: N/A

**TESTED BY** Name (capitals): [REDACTED]

Signature: [REDACTED]

Position: QS/PDH

Date: 10/10/2022

**TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION**

Supply to DB is from: (N/A)

Nominal voltage: (N/A) V No. of phases: (N/A)

Overcurrent protection device for the distribution circuit Type: (BS EN N/A)

Rating: (N/A) A

Associated RCD (if any) Type: (BS EN N/A)

 No. of poles: (N/A)  $I_{an}$  (N/A) mA Operating time: (N/A) ms

Characteristics at this DB Confirmation of supply polarity: (Yes)

 Phase sequence confirmed (where appropriate):   $Z_s$  (0.7)  $\Omega$    $Z_{pf}$  (0.33) kA

**TEST INSTRUMENTS**  
 (enter serial number against each instrument used)

Multi-function: (101909080) (N/A)

Insulation resistance: (N/A) (N/A)

Earth electrode resistance: (N/A) (N/A)

Continuity: (N/A) (N/A)

Earth fault loop impedance: (N/A) (N/A)

## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS								Circuits/equipment vulnerable to damage when testing: N/A																	
CODES For Type of wiring		(A) Thermoplastic insulated /		(B) Thermoplastic cables in		(C) Thermoplastic cables in		(D) Thermoplastic cables in		(E) Thermoplastic cables in		(F) Thermoplastic / SWA cables		(G) Thermosetting / SWA cables		(H) Mineral-insulated cables		(I) other - state		N/A					
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa		Max disconnection time (BS 7671) (s)	Protective device				RCD Operating current, $I_{an}$ (mA)	Maximum permitted $Z_s$ for installed protective device* ( $\Omega$ )	Circuit impedances ( $\Omega$ )				Insulation resistance			Polarity	Max. measured earth fault loop impedance, $Z_s$ ( $\Omega$ )	RCD operating time (ms)	Test buttons	
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			(Line) $r_1$	(Neutral) $r_n$	(cpc) $r_2$	( $R_1+R_2$ )	$R_2$	(MΩ)	(MΩ)	Test voltage DC (V)			RCD	AFDD
1	DISABLED TOILET AND KITCHEN LOBBY LIGHTS	A	B	N/A	1	1	0.4	3036 Fuse (SE)	2	5	2	N/A	9.1	N/A	N/A	N/A	1.41	N/A	LIM	LIM	LIM	1.73	N/A		
2	DALI CONTROL	A	B	N/A	1	1	0.4	3036 Fuse (SE)	2	5	2	N/A	9.1	N/A	N/A	N/A	0.01	N/A	LIM	LIM	LIM	0.33	N/A		
3	1ST CEILING GRID LIGHTS	A	B	N/A	1	1	0.4	3036 Fuse (SE)	2	5	2	N/A	9.1	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	LIM	N/A		
4	2ND CEILING GRID LIGHTS	A	B	N/A	1	1	0.4	3036 Fuse (SE)	2	5	2	N/A	9.1	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	LIM	N/A		
5	3RD CEILING GRID LIGHTS	A	B	N/A	1	1	0.4	3036 Fuse (SE)	2	5	2	N/A	9.1	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	LIM	N/A		
6	4TH CEILING GRID LIGHTS	A	B	N/A	1	1	0.4	3036 Fuse (SE)	2	5	2	N/A	9.1	N/A	N/A	N/A	LIM	N/A	LIM	LIM	LIM	LIM	N/A		

 DISTRIBUTION BOARD (DB) DETAILS  
(to be completed in every case)

DB designation: DB002-LIGHTING

Location of DB: KITCHEN CUPBOARD

TESTED BY Name (capitals): [REDACTED]

Signature: [REDACTED]

Position: QS/PDH

Date: 05/10/2022

## TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB1) Nominal voltage: (230) V No. of phases: (1)

Overcurrent protection device for the distribution circuit Type: (BS EN 60898) Rating: (32) A

 Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A)  $I_{an}$  (N/A) mA Operating time: (N/A) ms

 Characteristics at this DB Confirmation of supply polarity: (Yes) Phase sequence confirmed (where appropriate):   $Z_s$  (0.32)  $\Omega$   $Z_{pf}$  (0.72) kA

 TEST INSTRUMENTS  
(enter serial number against each instrument used)

Multi-function: (101909080) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: RCD: (N/A) (N/A)

## ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS										Circuits/equipment vulnerable to damage when testing: N/A															
CODES For Type of wiring				(A) Thermoplastic insulated /	(B) Thermoplastic cables in	(C) Thermoplastic cables in	(D) Thermoplastic cables in	(E) Thermoplastic cables in	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state	N/A												
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa		Max disconnection time (BS 7671) (s)	Protective device			RCD Operating current, $I_{an}$ (mA)	Maximum permitted $Z_s$ for installed protective device* ( $\Omega$ )	Circuit impedances ( $\Omega$ )				Insulation resistance			Polarity	Max. measured earth fault loop impedance, $Z_s$ ( $\Omega$ )	RCD operating time (ms)	Test buttons		
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)			(Line) $r_1$	(Neutral) $r_m$	(cpc) $r_2$	( $R_1+R_2$ )	Live / Earth	Live / Earth	Test voltage DC (V)				RCD	AFDD	
1	COUNCIL C H/P	A	B	N/A	6	2.5	0.4	60898 MCB	B	32	6	30	1.37	N/A	N/A	N/A	FI	N/A	LIM	LIM	LIM	✓	FI	32	✓
2	MAYOR P H/P	A	B	N/A	6	2.5	0.4	60898 MCB	B	32	6	30	1.37	N/A	N/A	N/A	FI	N/A	LIM	LIM	LIM	✓	FI	32	✓
3	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
4	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
5	COMBI SPUR	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	16	6	30	2.73	N/A	N/A	N/A	FI	N/A	LIM	LIM	LIM	✓	FI	32	✓
6	COUNCIL C SPUR	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	16	6	30	2.73	N/A	N/A	N/A	1.17	N/A	LIM	LIM	LIM	✓	1.52	32	✓
7	MAYOR P SPUR	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	16	6	30	2.73	N/A	N/A	N/A	FI	N/A	LIM	LIM	LIM	✓	FI	32	✓
8	CONTACTOR	A	B	N/A	2.5	1.5	0.4	60898 MCB	B	16	6	30	2.73	N/A	N/A	N/A	0.01	N/A	LIM	LIM	LIM	✓	0.36	32	✓

 DISTRIBUTION BOARD (DB) DETAILS  
(to be completed in every case)

DB designation: DB005-HEATING

Location of DB: N/A

TESTED BY Name (capitals): [REDACTED]

Signature: [REDACTED]

Position: QS/PDH

Date: 05/10/2022

## TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (N/A)

Nominal voltage: (N/A) V No. of phases: (N/A)

Overcurrent protection device for the distribution circuit Type: (BS EN N/A)

Rating: (N/A) A

Associated RCD (if any) Type: (BS EN N/A)

 No. of poles: (N/A)  $\Delta$  (N/A) mA Operating time: (N/A) ms

Characteristics at this DB Confirmation of supply polarity: (Yes)

 Phase sequence confirmed (where appropriate):   $Z_s$  (0.35)  $\Omega$    $Z_s$  (0.66)  $\Omega$ 

 TEST INSTRUMENTS  
(enter serial number against each instrument used)

Multi-function: (101909080) (N/A)

Insulation resistance: (N/A) (N/A)

Earth electrode resistance: (N/A) (N/A)

Continuity: (N/A) (N/A)

Earth fault loop impedance: (N/A) (N/A)



325218

IPR18

## ELECTRICAL INSTALLATION CONDITION REPORT

### ADDITIONAL NOTES

N/A

Original to the person ordering the work

(see additional page No. N/A)

# NOTES FOR RECIPIENT

## THIS CONDITION REPORT IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE USE

The purpose of periodic inspection is to determine, so far as is reasonably practicable, whether an electrical installation is in a satisfactory condition for continued service. This report provides an assessment of the condition of the electrical installation identified overleaf at the time it was inspected and tested, taking into account the stated extent of the installation and the limitations of the inspection and testing.

This report has been issued in accordance with the national standard for the safety of electrical installations, BS 7671: 2018 – Requirements for Electrical Installations.

The report identifies any damage, deterioration, defects and/or conditions found by the inspector which may give rise to danger (see PART 6), together with any items for which improvement is recommended.

If you were the person ordering this report, but not the user of the installation, you should pass this report, or a full copy of it including these notes, the schedules and additional pages (if any), immediately to the user.

This report should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this report will provide the new user with an assessment of the condition of the electrical installation at the time the periodic inspection was carried out.

Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested every six months. For safety reasons it is important that this instruction is followed.

**For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. NICEIC\* recommends that you engage the services of an NICEIC Approved Contractor for the inspection.**

The recommended date by which the next inspection should be carried out is stated in PART 5 of this report. There should also be a notice at or near the main switchboard or distribution board/consumer unit indicating when the next inspection of the installation is due.

Only an NICEIC Approved Contractor or Conforming Body is authorised to issue this NICEIC Electrical Installation Condition Report. You should have received the report marked 'Original' and the Approved Contractor should have retained the report marked 'Duplicate'.

This report form is intended to be issued only for the purpose of reporting on the condition of an existing electrical installation and must not be issued to certify new electrical installation work including the replacement of a distribution board or consumer unit.

The report consists of at least six numbered pages. Additional numbered pages may have been provided to permit further relevant information relating to the installation to be recorded. For installations having more than one distribution board or more circuits than can be recorded on PART 12, one or more additional Schedules of Circuit Details and Test Results should form part of the report. The report is invalid if any of the schedules identified in PART 10 are missing. The report has a printed seven-digit serial number, which is traceable to the Approved Contractor to which it was supplied by NICEIC.

PART 7 (Details and limitations) should identify fully the extent of the installation covered by this report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Operational limitations may have been encountered during the inspection such as inability to gain access to parts of the installation or to an item of equipment. The inspector should have noted any such limitations in PART 7. It should be noted that the greater the limitations applying to a report, the less its value from the safety aspect.

A declaration should have been given by the inspector in PART 4 of the report. The declaration must reflect the statement given in PART 3, which summarises the observations and recommendations made in PART 6. Where one or more observations have been made in PART 6, the Classification code given to each by the inspector indicates the degree of urgency with which remedial action needs to be taken to restore the installation to a safe working condition.

Where the inspector has indicated an observation as code C1 (danger present) the safety of those using the installation is at risk. Wherever practicable, items classified as (C1) should be made safe on discovery, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work immediately.

Where the inspector has indicated an observation as code C2 (potentially dangerous) the safety of those using the installation may be at risk, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where the inspector has indicated that an item requires further investigation (FI), the investigation should be carried out without delay to determine whether danger or potential danger exists. For further guidance on the Classification codes, please see the reverse of page 2.

Where the installation can be supplied by more than one source, such as the public supply and a standby generator or microgenerator, this should be identified in PART 8 Supply Characteristics and Earthing Arrangements, and the Schedules of Circuit Details and Test Results (PART 12) compiled accordingly.

Where inadequacies in the intake equipment have been observed (Item 1 of PART 10), the person ordering the inspection should inform the distributor and/or supplier as appropriate.

Should the person ordering this report have reason to believe that it does not reasonably reflect the condition of the electrical installation reported on, that person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the person ordering this report may make a formal complaint to NICEIC, for which purpose a complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

*\* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).*

For further information about electrical safety and how NICEIC can help you, visit [www.niceic.com](http://www.niceic.com)

# GUIDANCE FOR RECIPIENTS ON THE CLASSIFICATION CODES

**Only one Classification code should be given for each recorded Observation**

## **Classification code C1 (Danger present)**

Where an observation has been given a Classification code C1, the safety of those using the installation is at risk and immediate remedial action is required.

The person responsible for the maintenance of the installation is advised to take action without delay to remedy the observed deficiency in the installation, or to take other appropriate action (such as switching off and isolating the affected part(s) of the installation) to remove the danger. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

NICEIC makes available 'Electrical Danger Notification' forms to enable inspectors to record, and then to communicate to the person ordering the report, any dangerous condition discovered.

## **Classification code C2 (Potentially dangerous)**

Classification code C2 indicates that, whilst those using the installation may not be at immediate risk, urgent remedial action is required to remove potential danger. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

It is important to note that the recommendation given at PART 5 of this report (Next Inspection) for the maximum interval until the next inspection is conditional upon all items which have been given a Classification code C1 and code C2 being remedied immediately and as a matter of urgency, respectively.

It would not be reasonable for the inspector to indicate that the installation is in a satisfactory condition if any observation in this report has been given a code C1 or code C2 classification.

## **Classification code C3 (Improvement recommended)**

Where an observation has been given a Classification code C3, the inspection and/or testing has revealed a non-compliance with the current safety standard which, whilst not presenting immediate or potential danger, would result in a significant safety improvement if remedied. Careful consideration should be given to the safety benefits of improving these aspects of the installation. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

## **Code F1 (Further investigation required without delay)**

It should usually be possible for the inspector to attribute a Classification code to each observation without indicating a need for further investigation.

However, where 'F1' has been entered against an observation the inspector considers that further investigation of that observation is likely to reveal danger or potential danger that, due to the agreed extent or limitations of the inspection and/or testing, could not be fully identified at the time.

It would not be appropriate for the inspector to indicate that the installation is in a satisfactory condition if there is reasonable doubt as to whether danger or potential danger exists. Consequently, where the inspector has indicated 'Further investigation required without delay' (F1) the overall assessment of the installation (PART 3) should be marked as 'Unsatisfactory'.

If the inspector has indicated that an observation requires further investigation without delay, the person ordering this report is advised to arrange for the NICEIC Approved Contractor issuing the report (or another skilled person or persons competent in such work) to undertake further examination of that aspect of the installation as a matter of urgency, to determine whether or not danger or potential danger exists.

## **Further information**

Further information on the application of Classification codes, primarily aimed at inspectors but of possible interest to persons ordering condition reports, can be found in Electrical Safety First's Best Practice Guide No 4 Electrical installation condition reporting: Classification Codes for domestic and similar electrical installations. The guide can be viewed or downloaded free of charge from [www.electricalsafetyfirst.org.uk](http://www.electricalsafetyfirst.org.uk)

For further information about electrical safety and how NICEIC can help you, visit [www.niceic.com](http://www.niceic.com)